PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

JP MEDIA	Certificate reference PAT1	Number 20023

DETAILS OF CLIENT/LANDLORD

Client/ Address:	Bespoke Acoustic Duo

TEST EQUIPMENT DETAILS

Test Equipment used	Seaward PrimeTest100				
Tested by	John Phillips	Date	10/12/15	Retest Date	10/12/16

Serial Number	Make and model	Class	Voltage (V)	Rating (A)	Fuse rating (A)	Insulation resistance	Earth continuity	Plug, flex and body	OK to use ?
HCTL01 049	Yamaha Amplifier	Class1	240v			>19.99M^	I leak 0.50mA	Good	OK
IEC	IEC Mains Lead	Cord	240v	10A	!0A	>19.99M^	0.04 ohm	Good	OK
ED1533 8	Nord Keyboard	Class 1	240v	5A	5A	>19.99M^	I Leak 0.10mA	Good	OK
MAINS	Mains 3 block	Cord	240v	13A	13A	>19.99M^	0.05ohm	Good	OK
MAINS	Mains Figure of 8 cable	Cord	240v	5A	5A	>19.99M^	0.05ohm	Good	OK

Serial Number	Make and model	Location	Voltage (V)	Rating (A)	Fuse rating (A)	Insulation resistance	Earth continuity	Plug, flex and body	OK to use ?